

# 2020 Consumer Confidence Report Data

## HORICON WATERWORKS, PWS ID: 11401467

### Water System Information:

If you would like to know more about the information contained in this report, please contact Tim Kingman at (920) 485-3540.

### Opportunity for input on decisions affecting your water quality:

Public meetings are held on second Tuesday (PW Committee) and fourth Tuesday (Common Council) each month at City Hall (404 East Lake Street, Horicon, WI 53032) location.

### Source(s) of Water:

Source ID	Source	Depth (in feet)	Status
3	Groundwater	715	Active
4	Groundwater	786	Active
5	Groundwater	721	Active

To obtain a summary of the source water assessment please contact Tim Kingman at (920) 485-3540.

### Health Information:

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

### Educational Information:

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

**Definitions:**

<b>Term</b>	<b>Definition</b>
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

**Detected Contaminants:**

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

**Disinfection Byproducts:**

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Violation	Typical Source of Contaminant
TTHM (ppb)	DB1	80	0	2.4	2.4	No	By-product of drinking water chlorination
HAA5 (ppb)	DB2	60	60	0	0	No	By-product of drinking water chlorination

**Inorganic Contaminants:**

Contaminant (units)	MCL	MCLG	Level Found	Range	Violation	Typical Source of Contaminant
BARIUM (ppm)	2	2	0.110	0.086 - 0.110	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)	4	4	0.8	0.4 - 0.8	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
MERCURY (ppb)	2	2	0.0	0.0 - 0.0	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
NICKEL (ppb)	100		1.2000	0.0000 - 1.2000	No	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel, and alloy products.
SELENIUM (ppb)	50	50	2	0 - 2	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
SODIUM (ppm)	n/a	n/a	14.00	5.10 - 14.00	No	n/a

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.4200	0 of 20 results were above the action level.	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	3.90	0 of 20 results were above the action level.	No	Corrosion of household plumbing systems; Erosion of natural deposits

### Radioactive Contaminants:

Contaminant (units)	MCL	MCLG	Level Found	Range	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)	15	0	9.1	5.5 - 9.1	No	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)	5	0	3.6	1.7 - 4.2	No	Erosion of natural deposits
GROSS ALPHA, INCL. R & U (n/a)	n/a	n/a	9.2	5.7 - 9.2	No	Erosion of natural deposits
COMBINED URANIUM (ug/l)	30	0	0.4	0.0 - 0.4	No	Erosion of natural deposits

### Additional Health Information:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Horicon Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

### Availability of Consumer Confidence Report:

The Consumer Confidence Report may be provided without cost to Customers upon request {(920) 485-3500} and can be referenced at public locations where it is posted {City Hall (404 E Lake St), John Deere Office (110 W Lake St), Kwik Trip Stores (305 Barstow St and 716 E Lake St), Colonial Apartments (121 Colonial Dr), Marvin's Manor (839 Division St), Mother's Day Restaurant (417 E Lake St), Winchester Place Senior Living (713 Horicon St), Horicon Post Office (420 E Lake St), Horicon Hardware Hank Store (626 Washington St), or referenced on the City web page (<https://cithoriconwi.us/>).